

DOCUMENT RESUME

ED 445 484

EF 005 676

AUTHOR Callahan, Michael P.; Parker, Danny S.; Sherwin, John R.; Anello, Michael T.

TITLE Evaluation of Energy Efficiency Improvements to Portable Classrooms in Florida.

INSTITUTION Florida Solar Energy Center, Cape Canaveral.

SPONS AGENCY Florida State Dept. of Education, Tallahassee.

REPORT NO FSEC-CR-1133-99

PUB DATE 1999-11-00

NOTE 20p.

AVAILABLE FROM Florida Solar Energy Center, 1679 Clearlake Rd., Cocoa, FL 32922-5703. Web site:
<http://www.fsec.ucf.edu/~bdac/pubs/CR1133>.

PUB TYPE Guides - Non-Classroom (055) -- Reports - Research (143)

EDRS PRICE MF01/PC01 Plus Postage.

DESCRIPTORS Air Conditioning; *Educational Facilities Improvement; Elementary Secondary Education; *Energy Conservation; Lighting; Public Schools; *Relocatable Facilities; Roofing

IDENTIFIERS *Florida

ABSTRACT

Findings are presented from a 2-year experiment exploring ways to reduce energy costs and improve the learning environment in Florida's 25,000 portable classrooms. Improvements were made in two highly instrumented portable classrooms in the following areas: installation of a T8 lighting system with electronic ballasts; a high efficiency heat pump with enthalpy recovery ventilation (ERV); a metal white reflective roof system; and an occupancy based control system for lighting and air conditioning. Findings reveal the lighting system and occupancy control reduced lighting energy use by an average of 53 percent from one year to the next. The ERV provided five times the ventilation air found in the initial configuration, while still controlling indoor humidity to an acceptable level; this significantly cut internal CO2 levels with a potential beneficial impact on indoor air quality. Total reduction in space conditioning energy needs was 39 percent or about 6.9 kWh/day. The project demonstrates the feasibility of altering new portable classrooms in Florida so that they use 40 percent less electricity. Energy savings greater than 30 percent were demonstrated for existing portable classrooms through automated controls and simple changes to the lighting system. (Contains 21 references.) (GR)

On-line publications

Evaluation of Energy Efficiency Improvements to Portable Classrooms in Florida

November 1999
FSEC-CR-1133-99*

Submitted by

Michael P. Callahan
Danny S. Parker
John R. Sherwin
Michael T. Anello

Florida Solar Energy Center
1679 Clearlake Rd.
Cocoa, FL 32922-5703

PERMISSION TO REPRODUCE AND
DISSEMINATE THIS MATERIAL HAS
BEEN GRANTED BY

Suzanne Marshall

TO THE EDUCATIONAL RESOURCES
INFORMATION CENTER (ERIC)

U.S. DEPARTMENT OF EDUCATION
Office of Educational Research and Improvement
EDUCATIONAL RESOURCES INFORMATION
CENTER (ERIC)

This document has been reproduced as
received from the person or organization
originating it.

Minor changes have been made to
improve reproduction quality.

• Points of view or opinions stated in this
document do not necessarily represent
official OERI position or policy.

Table of Contents

Executive Summary

Introduction

Background

Site Description

Instrumentation

Lighting

Roofing

Heating, Ventilation and Air Conditioning (HVAC)

Baseline Energy Use and Related Characteristics

Cooling

Interior Humidity Levels

Ventilation Effectiveness

Lighting Energy Use

Evaluation of Retrofits

Lighting Retrofit

Windows

Heating, Ventilation and Air Conditioning

Occupancy Controls

Ventilation

HVAC Installation Quality

Roof Retrofit

Results

Seasonal Variation In Savings

ED 445 484

EF 005 676

Economics
Conclusions
References

Executive Summary

Florida has over 25,000 portable classrooms in use around the state. Energy costs for these structures exceed \$20 million a year - or about 11% of all energy-related expenditures for educational facilities. Research has also shown interior ventilation rates in these classrooms typically fall far below the recommended levels in ASHRAE Standard 62-1989.

To explore ways in which costs might be reduced and the physical learning environment improved, we conducted a two year experiment in two highly instrumented portable classrooms at Silver Sands Middle School in Volusia County. A series of retrofits, aimed to cut energy use and improve ventilation and illumination quality, were staged into the portables over time.

Within a year-long period of baseline monitoring, we verified that a typical Florida portable classroom used about 30 kWh/day. Measured energy end use was evenly split between lighting and space conditioning which accounted for more than 95% of total consumption (Figure E-1). We found that the baseline ventilation rate in the classrooms only to be about 2.6 cfm per student; daily carbon dioxide (CO₂) concentrations approached 2,500 ppm. Within the project, we demonstrated that several fundamental alterations in portable classroom equipment and roofing can produce very large reductions in total facility energy consumption. The specific improvements were:

- T8 lighting system with electronic ballasts
- A high efficiency heat pump with enthalpy recovery ventilation
- A metal white reflective roof system
- An occupancy based control system for lighting and air conditioning

These energy improvements have the large side benefit of potentially improving classroom indoor air quality and illuminance levels. The lighting system and occupancy control reduced lighting energy use by an average of 53% (7 kWh/day) from one year to the next. Total annual savings were estimated at 2,500 kWh, worth about \$200 at current electricity prices.

A package of measures - improved heat pump, an enthalpy recovery ventilator (ERV) and a reflective white roof - were incorporated to cut cooling energy use while providing higher levels of ventilation. The ERV was able to provide five times the ventilation air (13 cfm/student) found in the initial configuration, while still controlling indoor humidity to an acceptable level. This significantly cut internal CO₂ levels with a potentially beneficial impact on indoor air quality (Figure E-2). Total reduction in space conditioning energy needs was 39% or about 6.9 kWh/day. Annually, the 2,520 kWh savings is worth about \$200 in reduced operating costs.




Figure E-3. Total average daily energy demand in the year before (red) and after (green) retrofit. time of day energy savings are shown in blue. Total savings are 41%.

Figure E-3 shows the total impact of all the retrofits on daily energy consumption in Portable 035 from the baseline year to 1998-1999 when all retrofits were in place. Measured annual energy reduction for the overall project averaged 12.6 kWh/day for a reduction of 41%. Although miscellaneous consumption increased slightly in the year post retrofit, the total annual energy savings have a value of about \$370 a year in reduced operating expenses.

Our project conclusively demonstrates the feasibility of altering new portable classrooms in Florida so that they use 40% less electricity than standard practice. Energy savings greater than 30% were demonstrated for existing portable classrooms through automated controls and simple changes to the lighting system. If this alone were accomplished in all of Florida's existing portable classrooms, the reduction in annual energy related expenditures would exceed \$6 million.

The improvements were shown to be economic (rate of return on investment > 20%), both for retrofit of existing portables classrooms as well as for re-design of new facilities. Further, our results indicate important side benefits: better ventilation and potential indoor air quality as well as improved desktop illumination. Both improvements would enhance the learning environment.

Introduction

Under contract with the Florida Department of Education (FDOE), the Florida Solar Energy Center (FSEC) has performed a study to determine how significantly energy consumption in portable classrooms can be cost-effectively reduced. The purpose of this study was to determine if portable classrooms in Florida can be made more energy efficient either by retrofit or at the time of new portable construction.

Secondary objectives were to see if the learning environment could be improved as part of the efficiency measures. This included thermal comfort, ventilation and illumination quality. The evaluation was accomplished through test of chosen measures in occupied classrooms. Since economics were important both energy savings and costs were tracked.



Figure 1. Photographs of the identical portable classrooms monitored at Silver Sands Middle School in Port Orange, Florida. Portable 035 is on the right and 096 is on the left.

Two adjacent classrooms were monitored for a year to collect baseline data, then energy efficiency measures were installed to analyze the effectiveness of each retrofit over time.

Retrofits included:

- Lighting: T12 lamp-magnetic ballast lighting system replaced by a more efficient T8 lamp-electronic ballast lighting system.
- Roofing: Gray asphalt shingle roof replaced with a reflective white metal roof to reduce cooling loads related to heat transfer from classroom ceilings.
- Heating, Ventilation and Cooling (HVAC): A three ton wall hung heat pump was replaced with 2½ ton higher efficiency model.
- Ventilation: Enthalpy recovery ventilation system added to provide greater outdoor air while controlling indoor humidity and energy impacts.
- Automated Controls: Occupancy based controls to turn off space conditioning when the classroom is unoccupied.

Background

Demands for increased classroom space against budget restrictions have resulted in a greater number of installed portable classrooms in the Florida school system. Where these relocatable classrooms were once thought to be temporary structures, it is now accepted that they are more or less permanent (Florida Today, 1997).⁽¹⁾

Portable classrooms are often poorly received by the community (Stoddard, 1997). They are typically judged as substandard educational facilities and have been called "eyesores" and "monotonous and uninspiring" (Educational Facilities Lab, 1964). Such perceptions arise from the portables' bland coloration and their often shabby appearance (Rasmussen et. al., 1995).

Florida schools have an average of 9.9 portables with 836 ft² of conditioned floor area each (Callahan et al. 1997). There are over 2,500 schools in the state so that means approximately 25,000 portable classrooms are in use. In addition, the same study shows that each portable classroom uses approximately 10,840 kWh per year. This is corroborated by measured energy use at a central Florida elementary school of 360 kWh/day for 12 portables (Sherwin and

Parker 1996). Thus, both statistical estimates as well as monitoring shows an average use of about 30 kWh/day for portable classrooms.

Based on such data, portables account for 11% of the energy budget for Florida public schools. We estimate that portable energy use statewide was 250 million kWh costing \$20 million annually (Callahan et. al., 1997). The annual energy costs for Florida schools in 1995 was \$205 million, so portable classrooms contribute significantly to the cost of annual operation.

Simulation analysis in a study of potential portable classroom improvements suggests that energy savings may be reduced up to 23% with a payback of less than 3 years (Brown et. al., 1997). However, empirical verification of this potential and demonstration of measured savings in hot climates has been lacking.

To remedy this gap in knowledge, the Florida Solar Energy Center, in conjunction with the Florida Department of Education, chose a school upon which to conduct a real-world test. Silver Sands Middle School is located in Port Orange in the Volusia County School District. The school has 39 portable classrooms.

Site Description

Two portable classrooms with identical dimensions and configuration, numbers 035 and 096, were chosen for the study. The portable classrooms were of wood frame construction with shingle roofs and dark beige wood siding. They are rectangular in shape: 36 x 20 ft in an east-west orientation with north and south facing windows. The conditioned floor area is 720 ft². Three 4.1 ft x 6.5 ft single-glazed windows are located on both the north and south sides of the portables. The total window area is 156 ft² or 22% of the gross floor area. Insulation levels and other characteristics are summarized in Table 1.

Table 1
Description of Portable Classrooms

<u>Overall</u>	
Construction	Wood frame construction, medium-colored shingle roof, corrugated metal exterior siding. Mounted on metal frame approx. 18 inches above grade without skirting material (i.e. open crawl space).
Floor area	720 ft ² (20' x 36', long axis oriented north-to-south).
Glazing	22% of gross floor area, single pane casement.
<u>Insulation</u>	
Roof	0.09 BTU/h · ft ² · °F (R-11) [estimated]
Walls	0.02 BTU/h · ft ² · °F (R-5) [estimated]
Floor	None
<u>Baseline HVAC System</u>	
Cooling	Packaged wall-mounted, direct expansion (DX) heat pump 3.0 ton nominal capacity
Air Distribution	Constant volume
Supply Fan Control	Continuous fan operation (fan ON)
Thermostat Settings	75°F cooling, 70°F heating
Schedule	8:00 am - 5:00 pm, "off" night and weekends
<u>Internal Gains (peak)</u>	
Occupancy	30 ft ² /person (approx.)
Lighting	2,150 watts (3.0 W/ft ²), fluorescent bulbs with prismatic fixtures.
Receptacles	<100 watts (periodic usage of overhead projector, computer, etc.)
Schedule	8:25 am - 3:30 pm weekdays, with some teacher occupancy before and after regular class hours.

Instrumentation

Each portable classroom was fully instrumented with thermocouples that measured interior space, roof, decking and attic temperatures. The portables were also wired to measure how long the doors were opened. CO₂ sensors measure carbon dioxide concentrations, an indicator of relative occupancy. Due to the high density in portable classrooms, indoor pollutant concentrations are a concern. Generally CO₂ concentrations should be less than 1000 ppm in occupied buildings.

Project instrumentation also monitored total kWh, air conditioning (AC) kWh, and lighting kWh. A weather station at the site measured wind speed, ambient temperature, relative humidity, and solar insolation over a 24 hour period. Data averages and sums were stored by that data logger every 15 minutes. All this instrumentation was poled by a *Campbell CR10* data logger which downloaded over a dedicated telephone line each night.

Lighting

Lighting represents a large portion of the total annual energy consumption for Florida schools.

Lighting fixtures also produce a great deal of heat during their normal operation which increases the interior classroom sensible cooling load by an estimated average of 23% annually (Floyd et al 1995). Portables predominantly use T12 lamp-magnetic ballast lighting systems in their classrooms because they are the most inexpensive. However, newer slim-line T8 lamp-electronic ballast systems perform best in both commercial and educational facilities (Sherwin and Parker, 1996; Parker et al., 1996). These lamps combined with electronic ballasts consume less energy than T12 lamps with magnetic ballasts (58 W versus 90 W respectively in two-tube fixtures). They can also provide better desktop illumination than T12s with enhanced color rendering (McIlvaine et al., 1994).

For the lighting retrofit, the 24 fixtures in the portables with the old magnetic ballasts were replaced with 12 electronic ballasts wired in tandem. The T12 fluorescent tubes were then replaced with slim-line T8 lamps. Desk-top illumination levels were monitored pre and post retrofit.

Roofing

The portable classrooms monitored had A-frame roofs with gray asphalt shingle over 3/4" plywood decking. This is a common type of roofing used in portable classrooms around the state. The south facing segment of the roof is 36.25 x 11.75 ft. and the north facing segment is 36.25 x 15.75 ft. The north-facing section provides an overhang for a handicap accessible entranceway on this side of the building.

Roof replacement was performed since previous studies have shown that roof solar absorptance significantly impact interior temperatures and space cooling energy use even with ceiling insulation in place (Givoni, 1976). Dark roofs with low reflectivities increase peak interior plenum temperatures by 20 - 25°F and thus increase the need for space cooling by 15% or more in Florida's hot climate. Infrared thermographs of the roof on Portable 035 clearly shows the influence (Figure 2) of solar heat gain on the roof structure.

Even light colored asphalt shingles absorb solar radiation readily. The reflectivity of light gray asphalt shingles is 22%, black asphalt shingles is 5%, but for a white metal roof is 67% (Anderson et al., 1991; Parker et al., 1993). In a series of twelve before/after experiments, Parker et al. (1995) demonstrated a space cooling electricity reduction of approximately 19% in residential buildings changed to a reflective roof system. This suggested beneficial impacts for this project.

Heating, Ventilation and Air Conditioning (HVAC)

Inefficient lighting and roof solar absorptance increase sensible cooling loads. Generally, space cooling use makes up one-third of a school's energy budget. A poorly sized or poorly maintained cooling and heating system can lead to major problems with indoor air quality, bacterial contaminants, viruses, mold, spores, and pollen (Brown 1995).

In a recent survey (Callahan et al. 1997), 252 schools of 655 schools with utility data had an average of 7.9 cfm per student, but with a highly bi-modal distribution with many schools having a ventilation rate of 5 cfm/student while others have a ventilation rate of 15 cfm/student. The schools HVAC systems with a ventilation rate of 5 cfm/student are likely older, especially in older portables that were not brought up to the new ASHRAE 62-1989 standard. This new standard may contribute to indoor air quality (IAQ) problems since a higher outdoor air ventilation rate will often produce greater moisture problems since control is

difficult in such densely occupied spaces.

Evidence suggests ventilation provided in portable classrooms is considerably worse. Cooling systems in portable classrooms are predominantly wall-hung through-the-wall cooling systems, often providing no outside air due to closed or inoperable dampers.

Baseline Energy Use and Related Characteristics

Baseline energy data was collected from both portables from September of 1997 until May 20th of 1998. This essentially gave an entire school year of data on the relative performance of the portables. A basic summary of the energy use data is shown in Figures 3 and 4.

Figure 3 shows that the measured total energy use in Portable 035 averaged 31.4 kWh per day - very similar to the average measured in previously cited studies. The majority of energy consumption in the portables was for space cooling and lighting. Some 17.6 kWh per day or 56% was used for space conditioning. Of this, 14.0 kWh/day (44%) was consumed by space cooling and 3.6 kWh (13%) was used for heating. Mean lighting energy use was 13.1 kWh/day or 41% of total consumption. Plug loads for projectors, computers and an outdoor night light averaged 0.7 kWh/day or just 2% of total use.

Figure 4 shows a similar presentation of energy end-use analysis for Portable 096. Total energy use, averaging 19.1 kWh/day, was considerably less than Portable 35. Space conditioning energy use was much lower at 8.7 kWh/day (45% of total), partly due to higher temperatures maintained inside and a poorly functioning cooling system. The cooling system was the subject of a number of complaints from the instructor. Space cooling consumption was 6.7 kWh/day (35%) and heating was 10%. Lighting energy use at 9.5 kWh/day (50% of total) was also lower due to the teacher's frequent habit of turning off the perimeter lighting when using an overhead projector. Plug loads averaged 0.9 kWh/day or 5% of consumption.

Cooling

Figures 5 shows the average air conditioning electric demand profile at the two portables on weekdays during the school year. The higher demand at Portable 035 is clearly visible as is evidence of operation during non-occupied hours. These data suggests that automated controls may provide beneficial energy savings when used in portable classrooms.

Interior Humidity Levels

Figure 6 shows the average interior temperatures and relative humidity maintained in the two portables over the school year. These indexes are important as widely varying indoor temperatures can be a source for student and instructor complaints and high humidity levels are correlated with perceived indoor air quality problems (Arundel et. al., 1996; Callahan et. al., 1997). Note that the highest relative humidity levels are reached soon after full classroom occupancy at 9 AM when cooling system runtimes and associated machine moisture removal rates are low. In general, Portable 035 maintains significantly lower temperatures and relative humidities than its counterpart. Based on dissatisfaction from the instructor in Portable 096, part of this difference may be to poor function of the cooling system.

Ventilation Effectiveness

Figure 7 shows the typical weekday CO₂ concentration rate in the two classrooms. Carbon dioxide concentrations are a key parameter describing relative classroom ventilation rates. Research indicates that a 15 cfm/student ventilation rate is necessary to hold CO₂ rates below a recommended maximum of 1,000 parts per million (ppm) (Downing and Bayer, 1993). Note that CO₂ concentrations in both portables readily exceeded the 1000 ppm level by 11 AM and are sustained at over 1500 ppm from noon until 3 PM. We also observed that the CO₂ levels at Portable 035 dropped off more quickly than Portable 096 post occupancy.

Possible reasons for the lower post occupancy CO₂ decay rate in Portable 096 are shown in Figure 8. This plot depicts the number of seconds in each 15-minute recorded interval in which the classroom door was open. For instance, an average rate of 200 seconds would indicate that the door was open 22% of the time (200/900 seconds). Note that the door of Portable 035 is open much more frequently during late afternoon hours. This reflects the habit of the instructor of opening the door to the portable during the late afternoon hours of moderate days when students often come and go for tutoring.

Lighting Energy Use

Figure 9 compares the baseline lighting energy demand profiles for occupied days. Note that although average peak demand is similar (1200 Watts or approximately 1.7 W/ft²), the consumption in Portable 096 is lower, particularly after regular school hours. This indicates a behavioral difference between the portables in the tendency for consistent shutdown of overhead lighting during unoccupied evening hours.

Evaluation of Retrofits

Lighting Retrofit

The lighting system originally in place in the portables was a T12 lamp-magnetic ballast lighting system with 24 two-tube F40CW fixtures (~90 W each). The connected lighting load is approximately 2.16 kW. The T8 lamp-electronic ballast lighting system was installed in Portable 035 on May 21, 1998 and in Portable 096 on November 23, 1998. The new two-tube T8 fixtures draw about 58 Watts with ballasts (Figure 10).

As shown in Figure 11, the energy savings from the retrofit of the lighting system in Portable 035 was approximately 35% or 4.6 kWh on two matched days. The energy savings due to the retrofit for Portable 096 was very similar (Max load = 2,152 W for old system versus 1,276 W for new system).

Figure 12 is a comparison of energy use for the portables on March 10, 1999, which was during the post retrofit period for both portables. Portable 096 used 58.9% (6.4 kWh) less over the course of the day than Portable 035.

Generally, the instructor in Portable 096 operates fewer banks of lights during the day based on personal preference and extensive use of an overhead projector.

Lighting contributes significantly to the heat gain inside portable classrooms which affects cooling and heating energy consumption. Infrared thermographs were taken of the lighting system in Portable 035 prior to and following lighting retrofit (Figures 13 and 14 top of the

next page). In the thermograph, color is proportional to temperature with the darker colors being cooler and the lighter colors hotter. Figure 13 demonstrates the heat produced by the old lighting system. The temperature range for both of the figures is 75.5 to 93.2°F and it is seen that the T12 fixtures heat up to over 93°F. In Figure 14 the infrared thermograph of the T8 lamps show that they run cooler than the T12 lamps. The violet color is proportional to 75-77°F for the efficient lighting system. Note also the cooler ceiling temperature brought about by the reflective roofing system.

Not only did the T8 lighting system cut energy use by 35 - 40%, it also provided better illumination. Light level readings were taken before and after lighting retrofit. Minimum classroom desk-top illumination levels are 50 foot candles and Illuminating Engineering Society (IES) recommended lighting levels are approximately 70 foot candles for fine reading tasks (IES, 1988) (10.76 decalux = 1 foot candle). Pre-retrofit average desk-top illumination for the lighting in Portable 035 was 89.9 decalux while post retrofit average brightness was 93.3 decalux for a 4% increase in the average light level. The T8 system also provides excellent color rendering resulting in a better quality of illumination. Illumination can have physiological affects on student's ability to learn, (McKinley, 1991). Classrooms with superior illumination and particularly those with better daylight may provide a better educational environment (Hathaway et. al., 1992).

Windows

Another significant impact on both lighting and space conditioning energy use are windows and daylighting. Windows are a major source of solar heat gain in Florida. The optimal orientation of windows is north-south facing, which is observed with the two studied portables. However, it would also be ideal to have the larger overhang on the south half of the building. Furthermore, the portables obviously have issues with solar heat gain and glare because the windows were covered with blinds and construction paper to combat these problems. [Figure 15](#) shows the north windows of Portable 035. Note the construction paper attached to reduce glare, as well as the influence of insect screens on the bottom of the windows to provide better insolation of the windows. The white hot streak at the top is where the overhang meets the wall/roof sill plate.

To control glare and localized overheating in the classroom the teachers placed construction paper in the windows or have hung canvas from the ceilings to shade the windows. As demonstrated below by the infrared photos of the windows taken from inside, this crude strategy is somewhat effective ([Figure 16](#)). The temperature range is 62.5°F (darkest colors) to 98.5°F (lightest colors). Thus, changes the classroom windows to solar control glazing might be an appropriate energy and comfort related improvement to examine in future research.

Heating, Ventilation and Air Conditioning

Significant improvements in energy use and ventilation were obtained by replacing the space cooling and heating system. The original *Crispaire AVP36HPA* 3 ton wall-mount unit was changed out to a *Bard WH301-A* 2½ ton unit based on the reduced sensible cooling load from lighting and the roof/ceiling. Details on the system are provided in Appendix A. The schematic and function of the wall-mount Energy Recovery Ventilator (WERV-2A2) is described in Appendix B. The system was replaced in Portable 035 on June 17, 1998 and in Portable 096 on August 31, 1999 (see [Figure 17](#)). The actual field performance of air conditioning system at Portable 035 was audited before and after change out of the unit. This was accomplished by

measuring the power use and latent and sensible cooling of the equipment pre and post retrofit. A return air temperature of 76°F was maintained in both tests. The results and procedure are contained in Appendix D.

At an outdoor temperature of 80°F, the existing *Crispaire* three ton unit drew just over 3,950 Watts, producing a 19.3 degree temperature drop across the cooling coil and a sensible cooling rate of 18,933 Btu/hr. Return and supply air flow were measured with a Shortridge flow hood, indicating 981 cfm - considerably lower than the 1200 cfm which should be indicated for a three ton machine. Measured latent heat removal was 7,048 Btu/hr for a total capacity of 25,980 with an EER of 7.6 Btu/W with a sensible heat ratio (SHR) of 0.73.

Under similar outdoor conditions, the new 2½ ton *Bard* unit with the ERV drew 3,730 Watts producing a drop across the evaporator coil of 16.7 degrees with a coil air flow of 1,099 cfm. This represented a sensible cooling capacity of 18,353 Btu/hr with a latent heat removal measured at 7,909 Btu/hr for a total capacity of 26,260 Btu/hr. The estimated SHR was 0.70 - showing the superior latent heat removal of the new unit. The indicated EER was 8.7 Btu/W with the ERV in operation. Thus, the replacement unit showed a similar cooling capacity to the larger original HVAC with a 6% drop in electrical demand even with greater outdoor air being introduced.

For Portable 035 the typical savings were 45% on similar occupied school days. However, as shown in [Figure 18](#), much of the savings in Portable 035 are due to the automated control of the HVAC unit.

Occupancy Controls

The occupancy sensors function to turn the HVAC and lighting on when the portable is in use and consistently turned off during unoccupied periods. The setup uses two occupancy sensors (DT-100L and DT-200; [Figure 19](#)) manufactured by *Wattstopper Inc.* The controls use passive infrared and ultrasonic sensing to control the lights and HVAC operation. One control is located at the front of the classroom and another at the rear to ensure complete coverage of the space. Details of the system and configuration are contained in Appendix C.




Figure 19. DT-200 occupancy sensor.

BEST COPY AVAILABLE

The majority of the energy savings come during the unoccupied periods when the HVAC is off

after the retrofit, while during the pre-retrofit period the HVAC was cycling on and off 24 hours a day. However, this figure also points out that during peak time the new unit used about 5% less energy (~180 W) than the old unit. Also, much of the overall reduction is due to the roofing change and lower internal heat from the lighting although the individual impact is difficult to separate in this analysis.

Figure 20 depicts the air conditioner use on the two portable classrooms on a teacher work day where the classroom is only occupied for a few hours. Note the difference in energy use during unoccupied periods before 7 a.m. and after noon. The occupancy sensor control on the system in Portable 035 turns off the HVAC when the classroom is unoccupied while the unit on Portable 096 cycles on and off during these periods because there is no automated control. This illustrates the importance of automated controls in energy reductions because during these periods Portable 035 used 7% less energy than 096. During the occupied periods, the energy use of the portables is similar.

Ventilation

Interior carbon dioxide (CO₂) levels in densely occupied classrooms are a good indicator of potential for pollutant concentrations as well as ventilation quality. Previous experience has shown both elevated CO₂ levels >2,500 ppm in portable classrooms as well as indoor air quality complaints (IEQ Strategies, 1997; Shirey et. al., 1997).

The superior CO₂ control of the replacement HVAC was provided by the enthalpy recovery wheel which adds a large volume of outside air which was first cooled and dried by exhaust air prior to being introduced into the classroom (Figure 21). A comparison test of the air conditioning units was performed by measuring the rate of decay of a tracer gas (sulfur hexafluoride - SF₆) by a sensitive *Bruel and Kjar Model 1302* gas sampling unit (Figure 22).

The pre-retrofit AC unit provided a ventilation rate of 0.68 air changes per hour (ACH) while the new unit with the ERV had a ventilation rate of 3.38 ACH, an increase in effective ventilation of almost 500%! This translates to approximately 2.6 cfm/student for the old unit and 13.0 for the replacement system which much more closely complies with the ASHRAE 62-1989 standard.

The impact of the superior ventilation is demonstrated in Figure 23. The CO₂ concentrations (in parts per million) in Portable 096 decrease by 43% after the introduction of the ERV.

Despite this large increase in volume of ventilation air added to Portable 035, the interior relative humidity increased by only 7%. Figure 24 shows how the average interior humidity varied in the two portables over the two year monitoring period. Typically interior relative humidity would be raised by 10-15% by such an increase in outdoor air. However, the modest increase in humidity demonstrates the enhanced moisture control through the use of the enthalpy recovery system.

HVAC Installation Quality

Our study found that physical HVAC installation quality in portable classrooms may be poor. Figures 25 and 26 shows both a photo and a thermograph of the AC unit on Portable 035 before the HVAC retrofit showing the units loss of cool air as leaking supply air cools the exterior wall of the portable (blue to violet colors). As with the previous thermographs, color is proportional to temperature with the darker colors being cooler and the lighter colors hotter.

After the retrofit, this supply leakage problem was solved and all the cool air was effectively delivered to the interior.

This problem underscores the need to perform quality control on HVAC installations on portable classroom space conditioning systems.

Roof Retrofit

The roofs originally had gray asphalt shingles that were torn off and replaced with 5V-crimp reflective white metal roofing (Figure 27). Roof replacement for Portable 035 was completed in June 1998 and for Portable 096 the end of September 1999.

As shown in the plots below (Figure 28), the peak plenum temperatures above the classroom associated with the gray asphalt shingle roof were quite high. This is due to high solar irradiance combined with high solar absorptance of the shingles. The roof surface temperatures reached over 150°F. Roof plenum temperatures can have a substantial impact on both ceiling heat transfer and student comfort. Note how peak plenum temperatures are reached just after noon.

The roof system temperatures evidenced a dramatic decrease after roof replacement. The reduction in peak plenum temperatures with the new roof system were over 25°F reducing the need for mechanical cooling and improving thermal comfort in the classroom below (also shown in Figures 13, 14 and 28).

The impact of the reflective roof was assessed by examining how the cooling energy load varied during the week before and after the roof system retrofit in Portable 096. The roof replacement was performed in late September, 1999. No other changes were made to the portable during this time and temperature conditions were consistent pre and post to allow a reasonable comparison.

Figure 29 shows how the air conditioning load profile varied in the two weeks. Loads from midnight until 7 a.m. are very similar. Savings begin at approximately 9 a.m., greatly increasing in the period after lunch when average reductions of over 1400 Watts are observed in cooling peak demand. Cooling demand is also reduced during the early evening hours due to the lower plenum temperatures above the classroom. Based on the analysis, overall cooling energy savings are over 33%.

Results

Seasonal Variation In Savings

Comparison's for several months of the year were made for energy and lighting use for Portable 035 since post retrofit was available over an extended period. Figures 30 and 31 show the comparable results for each month for HVAC and lighting, respectively.

Lighting energy savings for the month of October were 44% (174 kWh) while for the HVAC system it was much larger in absolute terms (44% or 405 kWh). The total energy savings for the month of October was 44% (594 kWh). Florida schools often have their highest utility bills in October.

The energy savings for the month of November from the lighting system was 46% (142 kWh) while the AC savings was 9% (38 kWh). Total energy savings for November after the retrofit was 28% (150 kWh). The lower savings reflects less cooling energy demand in this month and less impact of the reflective roofing system.

The total energy savings for the month of December were 32% (140 kWh). Lighting savings were significant at 55% (138 kWh) while HVAC savings were only 2% (1 kWh). The minimal savings of the HVAC was due primarily to the ability to use natural ventilation for the month of December and the ambient temperature for the month pre-retrofit was 6°F cooler so heating may have been used more for some days in the morning.

The total energy savings for the month of January was 27% (145 kWh). Lighting savings were again significant with a 50% (196 kWh) energy reduction. However, HVAC use actually increased by 5% (44 kWh) in the post retrofit January. This was likely due to a greater use of heat in the mornings to warm up the portables coupled with the higher level of outdoor air being introduced.

Total energy savings for the month of February were 44% (794 kWh). Lighting energy savings were the greatest with a 63% (659 kWh) reduction. The savings associated with the HVAC system were 18.2% (44 kWh).

An energy reduction of 53% (589 kWh) was achieved in March. Lighting savings were 66% (419 kWh) and HVAC savings were 36% (170 kWh). The large lighting energy reduction is attributed to poor control after regular school hours in the pre-retrofit period (neglecting to turn off lights consistently).

The energy savings for the 2½ ton HVAC system varied more than lighting by month due to the variation in cooling energy demand and the changing impact of the reflective roofing system.

Economics

Below we summarize the monitoring results for each technology monitored within the project. We also describe the incremental expense of each measure based on installed costs collected within the project. Finally, we estimate the simple payback for each application, both for new portable classrooms and for existing ones.

The costs are much lower for most items if incorporated at the time of classroom manufacture. A good example is lighting. The base system consists of 24 two-tube fixtures with a magnetic ballast in each. The retrofit system consists of the same number of T8 tubes (48) which cost approximately \$1 more per unit than the T12 lamps. However, the electronic ballasts in the retrofit system cost twice as much per ballast (\$20 each), but are tandem wired so that only one ballast is used for every two fixtures. This reduces the cost in new applications to the incremental costs of the T8 lamps themselves. For retrofit, we assume that half a day will be required to make the necessary wiring and lamp changes - effort that is not expended when the system is configured in this fashion from the beginning. Thus for new portables the incremental cost for better lighting is only for the lamps themselves.

Table 2
Energy Savings of Each Efficiency Measure Projected

Over a Year for a Single Portable Classroom

Efficiency Measure Description	Annual Energy Savings kWh	Cost New	Simple Payback Yrs.	Cost Exist	Simple Payback Yrs.
T8 Lighting System	1,679	\$50	0.4	\$400	3.0
<u>Occupancy Control*</u>					
	876	\$300	4.3	\$400	5.7
Lighting	1,643	\$300	2.3	\$400	3.0
HVAC System	2,519	\$300	1.5	\$400	2.0
Both					
<u>AC/ Ventilation Package</u>					
Hi-efficiency Heat Pump	NA	\$1,035	NA	\$3,045	NA
w/ ERV ventilator	NA	\$ 700	NA	\$3,100	NA
White metal roof	910	\$1,735	24.0	\$6,145	NA
Total HVAC Package					
TOTAL PACKAGE	5,110	\$2,085	5.0	\$6,945	NA

All costs are incremental costs over lowest cost competing system.

* All cost data for the occupancy control includes \$100 for a service call to fine tune time delay and sensitivity for the application in a specific classroom.

Note, that the lighting and automated controls are extremely cost effective, both in new as well as existing applications. This indicates that substantial cost effective energy savings are potentially available in Florida's large stock of existing portable classrooms. These two measures alone show the potential to cut energy use by over 30% (11.5 kWh/day) with combined pay backs of less than three years.

The individual performance of the reflective roofing, more efficient heat pump and enthalpy recovery ventilation (ERV) system cannot be broken apart within the monitoring results. However, we know that the change in demand of the two air conditioning systems is only about 6% when operating and that the ERV, even though recovering both sensible and latent heat from the added outdoor air, is still adding moist, warm ventilation air which will increase cooling loads. Thus, most of the reduction in space cooling is coming from the white reflective roof and the lower level of sensible heat gains from the more efficient lighting. While the HVAC/roofing measures are not so cost effective as the lighting and controls retrofits, the combination is able to provide much greater ventilation levels and potentially improved indoor air quality while still reducing space conditioning energy costs.

Another advantage of the proposed reflective roofing system is the longevity of the metal

roofing. Based on data from roofing contractors, metal roofs of the type used in the project retrofit have a 30 year life expectancy compared with only 15 years for fiberglass shingle roofs (Roofer, 1997). This makes for a lower cost roofing system over the long run, based on re-roofing costs. The energy savings then become a side benefit.

The overall package of measures evaluated have an added costs of about \$2,100 when incorporated into new portable classroom manufacture. This investment produces energy savings which pays for the added cost within 5 years (equivalent to a 20% rate of return on investment). More importantly, the proposed technologies improve the learning environment. The effective indoor ventilation rate is increased to comply with ASHRAE Standard 62-1989, while desk-top illuminance levels and color rendering are improved by the more efficient lighting.

Conclusions

Our project conclusively demonstrates that straightforward alterations in portable classroom equipment and roofing can produce very large reductions in total facility energy consumption. A typical Florida portable classroom uses about 30 kWh/day as verified by our monitoring. Energy end use is evenly split between lighting and space air conditioning which accounts for more than 95% of total consumption. The following retrofits were installed into two classrooms:

- T8 lighting system with electronic ballasts
- A high efficiency heat pump with enthalpy recovery ventilation
- A metal white reflective roof system
- An occupancy based control system for lighting and air conditioning

These energy improvements have the large side benefit of potentially improving classroom indoor air quality and illuminance levels. The overall measured savings of the energy retrofits in the portable classrooms are summarized in three plots.

Figure 32 shows how the T8 lighting system and occupancy control reduced lighting energy use by an average of 53% (7 kWh/day) from one year to the next. The automated controls were found to be responsible for about 2.4 kWh (19%) of the savings. Total annual savings were estimated at 2,550 kWh, worth about \$200 at current electricity prices. Lighting energy savings were fairly consistent year round.




Figure 32. Time of day lighting energy demand in the year before (orange) and after (green) retrofit.

Figure 33 shows how the improved heat pump, white roof and reduced internal heat from the more efficient lighting was able to cut daytime space conditioning electrical demand while providing five times the ventilation air (13 cfm/student) found in the base situation. This cut internal CO₂ levels and with potentially beneficial impact on indoor air quality. Savings in space conditioning during the occupied period was 2.4 kWh/day or about a 14% reduction in daily energy use. The value of the occupancy controls was demonstrated in the large level of savings produced during unoccupied hours. This represented 4.5 kWh/day or a reduction in space conditioning of about 25%. Total reduction in space conditioning energy needs was 39% or about 6.9 kWh/day. Annually, the 2520 kWh savings is worth about \$200 in reduced operating costs.




Figure 33. Average space conditioning energy demand before (red) and after (green) retrofit. Savings come from a package of measures.

Figure 34 shows the total impact of all the retrofits on overall energy consumption in Portable 035 from the baseline year to the 1998-1999 when all retrofits were in place. Measured annual energy reduction for the overall project averaged 12.6 kWh/day for a reduction of 41%. Although miscellaneous consumption increased slightly in the year post retrofit, the total annual energy savings have a value of about \$370 a year in reduced operating expenses.

Our results demonstrate that it is very feasible to alter new portable classrooms in Florida so that they use 40% less electricity than standard practice. The improvements were shown to be cost effective, both for retrofit of existing portables classrooms as well as for re-design of new facilities. Further, our findings show important side benefits. Better ventilation and potential indoor air quality result from the HVAC improvements. Also, the more efficient lighting provides superior desk top illumination. Together, the measures not only save on energy related operating cost, but can also significantly enhance the learning environment.

Acknowledgements

We would like to thank the Florida Department of Education for their participation with this project. We thank Silver Sands Middle School for their continued enthusiasm throughout the project. Finally, we thank Manufacturers' Marketing Representatives Incorporated and Bard Manufacturing for providing the 2 1/2 ton heat pump units used for this project.

References

- Anderson, R. W., D. W. Yarbrough, R. S. Graves, and R. L. Wendt, 1991. "Preliminary assessment of radiation control coatings for buildings. Insulation Materials: Testing and Applications, 2d vol., ASTM STP 1116, R. S. Graves and D. C. Wysocki, eds. Philadelphia: American Society for Testing and Materials.
- Arundel, A., Sterling, E.M., Biggin, J.H. and Sterling, T.D., 1986. "Indirect Health Effects of Relative Humidity in Indoor Environments," Environmental Health Perspectives 65, p. 351-361.
- Brown, G.Z., D. Bjornson, J. Briscoe, S. Fremouw, P. Kumar, P. Larocque, D. Northcutt, Z. Wang, D. Rasmussen, K. Rasmussen, J. Stanard, 1997. "Design and Evaluation of Energy-Efficient Modular Classroom Structures, Phase II." University of Oregon, Eugene, OR and Modern Building Systems, Inc., Aumsville, OR.
- Callahan, M. P., D. S. Parker, W. L. Dutton, and J. E. R. McIlvaine, 1997. "Energy Efficiency for Florida Educational Facilities: The 1996 Energy Survey of Florida Schools". FSEC-CR-951-97, Florida Solar Energy Center Cocoa, FL.
- Downing, C. C. and C. W. Bayer, 1993. "Classroom Indoor Air Quality vs. Ventilation Rate," ASHRAE Transactions, Vol. 99, Pt. 2, American Society of Heating, Refrigerating and Air Conditioning Engineers, Atlanta, GA.
- Educational Facilities Laboratories, 1964. Educational School Facilities. New York: Author (ERIC Document Reproduction Service No. ED 066 846).
- Florida Department of Education, 1999. State Requirements for Educational Facilities, Chapter 7, Office of Educational Facilities, Tallahassee, FL.
- Florida Today, "Portable classrooms may be here to stay," Mary Shedden, March 3, 1997, p.1.
- Floyd, D., D. Parker, J. Sherwin, and J. E. R. McIlvaine, 1995. "Energy Efficiency Technology Demonstration Project for Florida Educational Facilities: Occupancy Sensor". FSEC-CR-867-95, Florida Solar Energy Center Cocoa, Florida.
- The Florida Center of Community Design and Research, 1993. "The use of relocatable classrooms in the public school districts of Florida." (A research report for the Florida Department of Education, Office of Educational Facilities). Tampa: University of South Florida, Nov. 16, 1993.
- Givoni, B., 1976. Man, Climate and Architecture. London : Applied Science Publishers Ltd.
- Hathaway, W.E., Hargreaves, J.A., Thompson, G.W. and Novitsky, D., 1992. "A Study into the Effects of Light on Children of Elementary School Age," Edmonton Department of Education, Alberta.
- IES, 1998. "Educational Facilities Lighting," RP-3-88, Illuminating Engineering Society, NY.

IEQ Strategies, 1997. "Investigators Look to Improve Ventilation in Portable Classrooms," Cutter Information Corporation.

"Metal Roofing," Tony Chiovare, Roofer Magazine, Business News Publishing, July, 1997, p. 48-49.

McKinley, J., 1991. "New Standards for Classroom Lighting," American School and University, May, 1991.

McIlvaine, J. E. R., M. Mallette, D. Parker, P. Lapujade, D. Floyd, L. Schrum, and T. Stedman, 1994. "Energy Efficiency Design for Florida Educational Facilities". Prepared for the Florida Department of Education, Florida Solar Energy Center Cocoa, Florida.

Parker, D. S., L. Schrum, J. K. Sonne, and T. C. Stedman, 1996. "Side-by-Side Testing of Commercial Office Lighting Systems: Two-Lamp Fluorescent Fixtures". FSEC-PF-301-96, Florida Solar Energy Center Cocoa, Florida.

Rasmussen, E., K. Rasumussen, J. Stanard, S. Bernhard, G. Z. Brown, J. Briscoe, J. Kline, P. Kumar, and Z. Wang, 1995. "Design and Evaluation of Energy Efficient Modular Classroom Structures". Modern Building Systems, Inc. Aumsville, Oregon and University of Oregon, Eugene, Oregon.

Sherwin, J. R. and D. S. Parker, 1996. "FLASTAR: Florida Alliance for Saving Taxes and Energy Resources". FSEC-CR-916-96, Florida Solar Energy Center Cocoa, Florida.

Shirey, III, D.B., R.A. Raustad, and M. Brassard, 1997. Evaluation of an Enthalpy Recovery Ventilator Installed in a Portable Classroom, FSEC-CR-972-97, Florida Solar Energy Center, Cocoa, FL.

Stoddard, B.C., 1997, "Public Schools Not Making the Grade," The Construction Specifier, September, p. 29-36.

¹ A move within Florida is in progress to limit the further expansion of portable classroom utilization through requirement of covered walkways to the facilities.

* Submitted to:

Suzanne Marshall
Florida Department of Education
Office of Educational Facilities
325 W. Gaines St., Rm. 1054
Tallahassee, FL 32399

BEST COPY AVAILABLE

On-line publications



U.S. Department of Education
Office of Educational Research and Improvement (OERI)
National Library of Education (NLE)
Educational Resources Information Center (ERIC)



NOTICE

Reproduction Basis



This document is covered by a signed "Reproduction Release (Blanket)" form (on file within the ERIC system), encompassing all or classes of documents from its source organization and, therefore, does not require a "Specific Document" Release form.



This document is Federally-funded, or carries its own permission to reproduce, or is otherwise in the public domain and, therefore, may be reproduced by ERIC without a signed Reproduction Release form (either "Specific Document" or "Blanket").

EFF-089 (3/2000)